



Microbac Laboratories, Inc., New York Division  
**CERTIFICATE OF ANALYSIS**

J0J2025

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Calcium Primary

Fred Hauck  
 20104 NYS Route 3  
 Watertown, NY 13601

Project / PO Number: N/A  
 Received: 10/23/2020  
 Reported: 11/20/2020

**Analytical Testing Parameters**

Client Sample ID:	60B	Collected By:	RF - Client
Sample Matrix:	Drinking Water	Collection Date:	10/20/2020 6:53
Lab Sample ID:	J0J2025-01		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0195	0.015 AL	0.0010	mg/L		11/04/20 0758	11/04/20 1351	LLW

Client Sample ID:	52	Collected By:	RF - Client
Sample Matrix:	Drinking Water	Collection Date:	10/20/2020 6:47
Lab Sample ID:	J0J2025-02		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.015 AL	0.0010	mg/L		11/04/20 0758	11/04/20 1356	LLW

Client Sample ID:	99	Collected By:	RF - Client
Sample Matrix:	Drinking Water	Collection Date:	10/20/2020 6:09
Lab Sample ID:	J0J2025-03		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.015 AL	0.0010	mg/L		11/04/20 0758	11/04/20 1358	LLW

Client Sample ID:	68	Collected By:	RF - Client
Sample Matrix:	Drinking Water	Collection Date:	10/20/2020 6:53
Lab Sample ID:	J0J2025-04		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/04/20 0758	11/04/20 1400	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 73	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-05		<b>Collection Date:</b> 10/20/2020 6:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/04/20 0758	11/04/20 1402	LLW

<b>Client Sample ID:</b> 56	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-06		<b>Collection Date:</b> 10/20/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0011	0.015 AL	0.0010	mg/L		11/04/20 0758	11/04/20 1403	LLW

<b>Client Sample ID:</b> 74	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-07		<b>Collection Date:</b> 10/20/2020 6:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0012	0.015 AL	0.0010	mg/L		11/04/20 0758	11/04/20 1409	LLW

<b>Client Sample ID:</b> 63	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-08		<b>Collection Date:</b> 10/20/2020 6:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0016	0.015 AL	0.0010	mg/L		11/04/20 0758	11/04/20 1411	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 38	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-09		<b>Collection Date:</b> 10/20/2020 6:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0021	0.015 AL	0.0010	mg/L		11/04/20 0758	11/04/20 1413	LLW

<b>Client Sample ID:</b> 72	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-10		<b>Collection Date:</b> 10/20/2020 6:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/04/20 0758	11/04/20 1414	LLW

<b>Client Sample ID:</b> 78	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-11		<b>Collection Date:</b> 10/20/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0013	0.015 AL	0.0010	mg/L		11/04/20 0758	11/04/20 1416	LLW

<b>Client Sample ID:</b> 30	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-12		<b>Collection Date:</b> 10/20/2020 6:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0036	0.015 AL	0.0010	mg/L		11/04/20 0758	11/04/20 1420	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 31	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-13		<b>Collection Date:</b> 10/20/2020 6:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0030	0.015 AL	0.0010	mg/L		11/04/20 0758	11/04/20 1422	LLW

<b>Client Sample ID:</b> 81	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-14		<b>Collection Date:</b> 10/20/2020 7:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0013	0.015 AL	0.0010	mg/L		11/04/20 0758	11/04/20 1424	LLW

<b>Client Sample ID:</b> 50	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-15		<b>Collection Date:</b> 10/20/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0096	0.015 AL	0.0010	mg/L		11/04/20 0758	11/04/20 1425	LLW

<b>Client Sample ID:</b> 51	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-16		<b>Collection Date:</b> 10/20/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0041	0.015 AL	0.0010	mg/L		11/04/20 0758	11/04/20 1431	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 45	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-17		<b>Collection Date:</b> 10/20/2020 6:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0041	0.015 AL	0.0010	mg/L		11/04/20 0758	11/04/20 1433	LLW

<b>Client Sample ID:</b> 35B	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-18		<b>Collection Date:</b> 10/20/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.0158</b>	0.015 AL	0.0010	mg/L		11/04/20 0758	11/04/20 1435	LLW

<b>Client Sample ID:</b> 69	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-19		<b>Collection Date:</b> 10/20/2020 6:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/04/20 0758	11/04/20 1436	LLW

<b>Client Sample ID:</b> 85	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-20		<b>Collection Date:</b> 10/20/2020 7:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/04/20 0758	11/04/20 1438	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 54	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-21		<b>Collection Date:</b> 10/20/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0013	0.015 AL	0.0010	mg/L		11/04/20 0759	11/04/20 1447	LLW

<b>Client Sample ID:</b> 9	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-22		<b>Collection Date:</b> 10/20/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0026	0.015 AL	0.0010	mg/L		11/04/20 0759	11/04/20 1453	LLW

<b>Client Sample ID:</b> 24	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-23		<b>Collection Date:</b> 10/20/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0018	0.015 AL	0.0010	mg/L		11/04/20 0759	11/04/20 1455	LLW

<b>Client Sample ID:</b> 19	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-24		<b>Collection Date:</b> 10/20/2020 6:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0019	0.015 AL	0.0010	mg/L		11/04/20 0759	11/04/20 1457	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 18	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-25		<b>Collection Date:</b> 10/20/2020 6:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0039	0.015 AL	0.0010	mg/L		11/04/20 0759	11/04/20 1458	LLW

<b>Client Sample ID:</b> 70	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-26		<b>Collection Date:</b> 10/20/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0012	0.015 AL	0.0010	mg/L		11/04/20 0759	11/04/20 1500	LLW

<b>Client Sample ID:</b> 67	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-27		<b>Collection Date:</b> 10/20/2020 6:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/04/20 0759	11/04/20 1506	LLW

<b>Client Sample ID:</b> 35	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-28		<b>Collection Date:</b> 10/20/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0028	0.015 AL	0.0010	mg/L		11/04/20 0759	11/04/20 1508	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 79	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-29		<b>Collection Date:</b> 10/20/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0045	0.015 AL	0.0010	mg/L		11/04/20 0759	11/04/20 1509	LLW

<b>Client Sample ID:</b> 42	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-30		<b>Collection Date:</b> 10/20/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0140	0.015 AL	0.0010	mg/L		11/04/20 0759	11/04/20 1511	LLW

<b>Client Sample ID:</b> 71	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-31		<b>Collection Date:</b> 10/20/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/04/20 0759	11/04/20 1513	LLW

<b>Client Sample ID:</b> 66	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-32		<b>Collection Date:</b> 10/20/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/04/20 0759	11/04/20 1517	LLW





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 23	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-33		<b>Collection Date:</b> 10/20/2020 6:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0038	0.015 AL	0.0010	mg/L		11/04/20 0759	11/04/20 1519	LLW

<b>Client Sample ID:</b> 77	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-34		<b>Collection Date:</b> 10/20/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0015	0.015 AL	0.0010	mg/L		11/04/20 0759	11/04/20 1520	LLW

<b>Client Sample ID:</b> 26	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-35		<b>Collection Date:</b> 10/20/2020 6:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0027	0.015 AL	0.0010	mg/L		11/04/20 0759	11/04/20 1522	LLW

<b>Client Sample ID:</b> 29	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-36		<b>Collection Date:</b> 10/20/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/04/20 0759	11/04/20 1528	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 60A	<b>Collected By:</b> RF - Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:53
<b>Lab Sample ID:</b> J0J2025-37	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0146	0.015 AL	0.0010	mg/L		11/04/20 0759	11/04/20 1530	LLW

<b>Client Sample ID:</b> 75	<b>Collected By:</b> RF - Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 7:00
<b>Lab Sample ID:</b> J0J2025-38	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0016	0.015 AL	0.0010	mg/L		11/04/20 0759	11/04/20 1531	LLW

<b>Client Sample ID:</b> 83	<b>Collected By:</b> RF - Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 7:03
<b>Lab Sample ID:</b> J0J2025-39	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0016	0.015 AL	0.0010	mg/L		11/04/20 0759	11/04/20 1533	LLW

<b>Client Sample ID:</b> 84	<b>Collected By:</b> RF - Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 7:04
<b>Lab Sample ID:</b> J0J2025-40	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0017	0.015 AL	0.0010	mg/L		11/04/20 0759	11/04/20 1535	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 107	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-41		<b>Collection Date:</b> 10/20/2020 6:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0010	0.015 AL	0.0010	mg/L		11/04/20 1039	11/04/20 1135	LLW

<b>Client Sample ID:</b> 12	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-42		<b>Collection Date:</b> 10/20/2020 6:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0034	0.015 AL	0.0010	mg/L		11/04/20 1039	11/04/20 1140	LLW

<b>Client Sample ID:</b> 102	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-43		<b>Collection Date:</b> 10/20/2020 6:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0021	0.015 AL	0.0010	mg/L		11/04/20 1039	11/04/20 1142	LLW

<b>Client Sample ID:</b> 58	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-44		<b>Collection Date:</b> 10/20/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0011	0.015 AL	0.0010	mg/L		11/04/20 1039	11/04/20 1144	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 48	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-45		<b>Collection Date:</b> 10/20/2020 6:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0072	0.015 AL	0.0010	mg/L		11/04/20 1039	11/04/20 1146	LLW

<b>Client Sample ID:</b> 44	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-46		<b>Collection Date:</b> 10/20/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0039	0.015 AL	0.0010	mg/L		11/04/20 1039	11/04/20 1148	LLW

<b>Client Sample ID:</b> 96	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-47		<b>Collection Date:</b> 10/20/2020 6:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0019	0.015 AL	0.0010	mg/L		11/04/20 1039	11/04/20 1153	LLW

<b>Client Sample ID:</b> 3	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-48		<b>Collection Date:</b> 10/20/2020 6:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0074	0.015 AL	0.0020	mg/L	D	11/04/20 1319	11/06/20 1043	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 10	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-49		<b>Collection Date:</b> 10/20/2020 6:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0044	0.015 AL	0.0010	mg/L		11/04/20 1039	11/04/20 1155	LLW

<b>Client Sample ID:</b> 22	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-50		<b>Collection Date:</b> 10/20/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0029	0.015 AL	0.0010	mg/L		11/05/20 1429	11/05/20 2054	LLW

<b>Client Sample ID:</b> 105	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-51		<b>Collection Date:</b> 10/20/2020 6:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/04/20 1355	11/04/20 1544	LLW

<b>Client Sample ID:</b> 5	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-52		<b>Collection Date:</b> 10/20/2020 6:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0018	0.015 AL	0.0010	mg/L		11/04/20 1355	11/04/20 1550	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 97	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-53		<b>Collection Date:</b> 10/20/2020 6:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0027	0.015 AL	0.0010	mg/L		11/04/20 1355	11/04/20 1552	LLW

<b>Client Sample ID:</b> 92	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-54		<b>Collection Date:</b> 10/20/2020 6:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0043	0.015 AL	0.0010	mg/L		11/04/20 1355	11/04/20 1553	LLW

<b>Client Sample ID:</b> 94	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-55		<b>Collection Date:</b> 10/20/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0023	0.015 AL	0.0010	mg/L		11/04/20 1355	11/04/20 1555	LLW

<b>Client Sample ID:</b> 4	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-56		<b>Collection Date:</b> 10/20/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0023	0.015 AL	0.0010	mg/L		11/04/20 1355	11/04/20 1557	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 103	<b>Collected By:</b> RF - Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:10
<b>Lab Sample ID:</b> J0J2025-57	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0011	0.015 AL	0.0010	mg/L		11/04/20 1355	11/04/20 1603	LLW

<b>Client Sample ID:</b> 98	<b>Collected By:</b> RF - Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:08
<b>Lab Sample ID:</b> J0J2025-58	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0022	0.015 AL	0.0010	mg/L		11/04/20 1355	11/04/20 1605	LLW

<b>Client Sample ID:</b> 100	<b>Collected By:</b> RF - Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:09
<b>Lab Sample ID:</b> J0J2025-59	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0020	0.015 AL	0.0020	mg/L	D	11/04/20 1355	11/05/20 2027	LLW

<b>Client Sample ID:</b> 46	<b>Collected By:</b> RF - Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:49
<b>Lab Sample ID:</b> J0J2025-60	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0043	0.015 AL	0.0010	mg/L		11/04/20 1355	11/04/20 1608	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 1	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-61		<b>Collection Date:</b> 10/20/2020 6:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0055	0.015 AL	0.0020	mg/L	D	11/04/20 1355	11/05/20 2031	LLW

<b>Client Sample ID:</b> 104	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-62		<b>Collection Date:</b> 10/20/2020 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0051	0.015 AL	0.0051	mg/L	D	11/04/20 1355	11/05/20 2041	LLW

<b>Client Sample ID:</b> 93	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-63		<b>Collection Date:</b> 10/20/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0032	0.015 AL	0.0010	mg/L		11/04/20 1355	11/04/20 1615	LLW

<b>Client Sample ID:</b> 8	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-64		<b>Collection Date:</b> 10/20/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0026	0.015 AL	0.0010	mg/L		11/04/20 1355	11/04/20 1617	LLW





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 89	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-65		<b>Collection Date:</b> 10/20/2020 6:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0046	0.015 AL	0.0010	mg/L		11/04/20 1355	11/04/20 1619	LLW

<b>Client Sample ID:</b> 11	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-66		<b>Collection Date:</b> 10/20/2020 6:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0018	0.015 AL	0.0010	mg/L		11/04/20 1355	11/04/20 1625	LLW

<b>Client Sample ID:</b> 16	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-67		<b>Collection Date:</b> 10/20/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0024	0.015 AL	0.0010	mg/L		11/04/20 1355	11/04/20 1627	LLW

<b>Client Sample ID:</b> 28	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-68		<b>Collection Date:</b> 10/20/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0024	0.015 AL	0.0010	mg/L		11/04/20 1355	11/04/20 1628	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 21	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-69		<b>Collection Date:</b> 10/20/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0022	0.015 AL	0.0010	mg/L		11/04/20 1355	11/04/20 1630	LLW

<b>Client Sample ID:</b> 7	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-70		<b>Collection Date:</b> 10/20/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0023	0.015 AL	0.0010	mg/L		11/04/20 1355	11/04/20 1632	LLW

<b>Client Sample ID:</b> 15	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-71		<b>Collection Date:</b> 10/20/2020 6:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0061	0.015 AL	0.0010	mg/L		11/04/20 1357	11/04/20 1641	LLW

<b>Client Sample ID:</b> 101	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-72		<b>Collection Date:</b> 10/20/2020 6:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0012	0.015 AL	0.0010	mg/L		11/04/20 1357	11/04/20 1647	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 109	<b>Collected By:</b> RF - Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:30
<b>Lab Sample ID:</b> J0J2025-73	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0011	0.015 AL	0.0010	mg/L		11/04/20 1357	11/04/20 1649	LLW

<b>Client Sample ID:</b> 37	<b>Collected By:</b> RF - Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:40
<b>Lab Sample ID:</b> J0J2025-74	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0027	0.015 AL	0.0010	mg/L		11/04/20 1357	11/04/20 1651	LLW

<b>Client Sample ID:</b> 32	<b>Collected By:</b> RF - Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:30
<b>Lab Sample ID:</b> J0J2025-75	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0043	0.015 AL	0.0010	mg/L		11/04/20 1357	11/04/20 1652	LLW

<b>Client Sample ID:</b> 95	<b>Collected By:</b> RF - Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:06
<b>Lab Sample ID:</b> J0J2025-76	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0013	0.015 AL	0.0010	mg/L		11/04/20 1357	11/04/20 1654	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 2	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-77		<b>Collection Date:</b> 10/20/2020 6:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0076	0.015 AL	0.0010	mg/L		11/04/20 1357	11/04/20 1700	LLW

<b>Client Sample ID:</b> 17	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-78		<b>Collection Date:</b> 10/20/2020 6:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0024	0.015 AL	0.0010	mg/L		11/04/20 1357	11/04/20 1702	LLW

<b>Client Sample ID:</b> 49	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-79		<b>Collection Date:</b> 10/20/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0041	0.015 AL	0.0010	mg/L		11/04/20 1357	11/04/20 1704	LLW

<b>Client Sample ID:</b> 6	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-80		<b>Collection Date:</b> 10/20/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0023	0.015 AL	0.0010	mg/L		11/04/20 1357	11/04/20 1705	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 33	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-81		<b>Collection Date:</b> 10/20/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/04/20 1357	11/04/20 1707	LLW

<b>Client Sample ID:</b> 43	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-82		<b>Collection Date:</b> 10/20/2020 6:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0012	0.015 AL	0.0010	mg/L		11/04/20 1357	11/04/20 1711	LLW

<b>Client Sample ID:</b> 64	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-83		<b>Collection Date:</b> 10/20/2020 6:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0049	0.015 AL	0.0010	mg/L		11/04/20 1357	11/04/20 1713	LLW

<b>Client Sample ID:</b> 76	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-84		<b>Collection Date:</b> 10/20/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0013	0.015 AL	0.0010	mg/L		11/04/20 1357	11/04/20 1715	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 36	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-85		<b>Collection Date:</b> 10/20/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0021	0.015 AL	0.0010	mg/L		11/04/20 1357	11/04/20 1717	LLW

<b>Client Sample ID:</b> 87	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-86		<b>Collection Date:</b> 10/20/2020 7:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0012	0.015 AL	0.0010	mg/L		11/04/20 1357	11/04/20 1722	LLW

<b>Client Sample ID:</b> 34	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-87		<b>Collection Date:</b> 10/20/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0028	0.015 AL	0.0010	mg/L		11/04/20 1357	11/04/20 1724	LLW

<b>Client Sample ID:</b> 47	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-88		<b>Collection Date:</b> 10/20/2020 6:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0055	0.015 AL	0.0010	mg/L		11/04/20 1357	11/04/20 1726	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

<b>Client Sample ID:</b> 39	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-89		<b>Collection Date:</b> 10/20/2020 6:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0031	0.015 AL	0.0010	mg/L		11/04/20 1357	11/04/20 1728	LLW

<b>Client Sample ID:</b> 61	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-90		<b>Collection Date:</b> 10/20/2020 7:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0048	0.015 AL	0.0010	mg/L		11/04/20 1357	11/04/20 1730	LLW

<b>Client Sample ID:</b> 62	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF - Client
<b>Lab Sample ID:</b> J0J2025-91		<b>Collection Date:</b> 10/20/2020 7:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0046	0.015 AL	0.0010	mg/L		11/04/20 1404	11/04/20 1826	LLW

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL:** US EPA Action Level
- D:** The sample was diluted due to matrix interference.
- mg/L:** Milligrams per Liter
- RL:** Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2025

**Report Comments**

*Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.*

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

**Reviewed and Approved By:**

A handwritten signature in black ink that reads "Sara Lechleitner".

Sara Lechleitner

Customer Relationship Coordinator

Reported: 11/20/2020 12:14



3821 Buck Drive  
 Cortland NY 13045  
 Phone: (607)753-3403 Fax: (607)753-3415  
 NY #10795, EPA #NY00935

# Microbac Laboratories, Inc.

## CHAIN OF CUSTODY

Samples must be returned on ice  
 MNY Workorder #

*Calcium Primary*

**Billing/Invoices**

**Client Information**  
 Name: Jeff/Lew Boces  
 Address: 20104 NYS Route 3  
 Contact: Health/Safety Dept.  
 Phone: 315-779-7000  
 Project: Lead Testing  
 Quote ID: PO#  
 Rush TAT Bus. Days: 2-5 5-7 7-10  
 Carbon Copy: Yes  
 Email Results: Yes  
 Fax Results: Yes

rilley@boces.com, fhauck@boces.com, lshaw@boces.com

**Analysis Requested**

Receiving Info (Lab Use Only)  
 Ice: YES NO  
 Coolers: YES NO  
 Sample Temp:  
 Cooler seal: YES NO  
 Pickup: YES NO  
 Dropoff: C W  
 Accepted?: YES NO  
 Container Material  
 Container size (in MI)  
 Preservative

Sample Information		Matrix		Date	Time	Number of Containers for Analysis Requested	Comments/Field Data
Description/Location		Type					
600 B		DW		10/20	653	1	
52					647		
99					609		
68					653		
73					659		
519					645		
77					658		
63					659		
38					639		
72					657		
28					700		
30					682		
31					634		
31					706		
50					650		
51					645		
45					640		
35B					635		
69					653		
85					705		

J 0 J 2 0 2 5  
 Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE  
 PM: Shannon Weeks

**Comments**

Sampled: *[Signature]* Date/Time: 10/20/2020  
 Received: *[Signature]* Date/Time: 10/20/2020

Microbac Laboratories (MNY) may be liable for damages if you do not follow the instructions on this form. This document is the property of Microbac Laboratories and is not to be distributed outside of your organization.

**Microbac Laboratories, Inc.** Samples must be returned on ice  
**CHAIN OF CUSTODY** MNY Workorder #

3821 Buck Drive  
 Cortland NY 13045  
 Phone: (607) 753-3403 Fax: (607) 753-3415  
 NY #10795, EPA #NY008935

**Calcium Primary**

<b>Client Information</b>		<b>Billing/Invoice:</b>	
Name:	Jeff/Lew Bocces		
Address:	20104 NYS Route 3		
Contact:	Health/Safety Dept.		
Phone:	315-779-7000		
Project:			
Quote ID:	Lead Testing	PO#:	
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req.:	
Carbon Copy:	Yes		
Email Results:	Yes		
Fax Results:	Yes		
	rfilley@bocces.com, fhauck@bocces.com, lshaw@bocces.com		
<b>Sample Information</b>		<b>Matrix</b>	
Description/Location	Date	Time	Type
54	10/20	645	DW
9		620	
24		625	
19		628	
18		628	
70		655	
67		653	
35		635	
79		700	
42		655	
71		655	
66		655	
23		626	
77		700	
26		628	
29		630	
60A		653	
75		700	
83		703	
84		704	
Print Name and Company		Date/Time	Comment
		10/20/2020	
Sampled:			
Received:			
Received:			

<b>Receiving Info (Lab Use Only)</b>	
Ice:	YES NO
Cooler:	YES NO
Sample Temp:	
Cooler Seal:	YES NO
Pickup:	YES NO
Dropoff:	C W
Accepted?	YES NO
Container Material	
Container Size (in MI)	
Preservative	
<b>Comments/Field Data</b>	

<b>Analysis Requested</b>		<b>Number of Containers for Analysis Requested</b>	
Total Lead (EPA 200.8)			
Plastic			
250 ml			
HNO3			
1			

Microbac Laboratories (MNY) provides this report for the purpose of information only. We will not be responsible for any analysis or interpretation of results. The client is responsible for the accuracy of the data. The client is responsible for the accuracy of the data. The client is responsible for the accuracy of the data.

**Microbac Laboratories, Inc.**  
**CHAIN OF CUSTODY**

3821 Buck Drive  
 Cortland NY 13046  
 Phone: (607) 753-3403 Fax: (607) 753-3415  
 NY #10796, EPA #NY00836

Samples must be returned on ice  
 MNY Workorder #

*Calcium Primary*

Client Information		Billing/Invoices:		Analytix Requested		Receiving Info (Lab Use Only)	
Name:	Jeff/Lew Boces					Ice:	YES NO
Address:	20104 NYS Route 3					Cooler:	YES NO
Contact:	Health/Safety Dept.					Sample Temp:	YES NO
Phone:	315-779-7000					Cooler seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:		PO#:				Dropoff:	C W
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req:				Accepted?	YES NO
Carbon Copy:	Yes					Container Material	
Email Results:	Yes					Container Size (in MI)	
Fax Results:	Yes					Preservative	
Sample Information		Matrix		Number of Containers for Analytix Requested		Comments/Field Data	
Description/Location	Date	Time	Type				
107	10/20	6:14	DW				
12		6:23					
102		6:07					
58		6:45					
48		6:47					
44		6:50					
96		6:07					
3		6:00					
10		6:22					
22		6:25					
105		6:14					
5		6:08					
97		6:04					
92		6:05					
94		6:20					
4		6:18					
103		6:08					
98		6:09					
100		6:14					
416							
Total Lead (EPA 200.8)				1			
Plastic				250 ml			
FIN03							

Print Name and Company  
 Sampled: *Lay*  
 Received: *Filey*  
 Date/Time: 10/20/2000  
 Comments:

Microbac Laboratories (MNY) may be unable to perform portion of the requested analysis if the sample is not submitted to the laboratory within the time frame specified in the Chain of Custody form. It is the responsibility of the client to submit the sample to the laboratory within the time frame specified in the Chain of Custody form.

3821 Buck Drive  
Cortland NY 13045  
Phone:(607)753-3403 Fax:(607)753-3415  
NY #10795, EPA #NY00835

**Microbac Laboratories, Inc.** Samples must be returned on ice  
**CHAIN OF CUSTODY** MNY Workorder #

**Calcium PRIMARY**

<b>Client Information</b>		<b>Billing/Invoices:</b>	
Name:	Jeff/Lew Boces		
Address:	20104 NYS Route 3		
Contact:	Health/Safety Dept.		
Phone:	315-779-7000		
Project:			
Quote ID:	Lead Testing	PO#:	
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req.:	
Carbon Copy:	Yes		
Email Results:	Yes		
Fax Results:	Yes		

<b>Sample Information</b>		<b>Matrix</b>	
Description/Location	Date	Time	Type
104	10/20	6:00	DW
93		6:10	
89		6:05	
77		6:30	
11		6:10	
119		6:22	
28		6:25	
21		6:35	
7		6:25	
15		6:20	
101		6:24	
109		6:09	
37		6:30	
32		6:46	
95		6:30	
77		6:06	
49		6:01	
		6:27	
		6:45	
		6:20	

Sample Information		Matrix		Analysis Requested		Receiving Info (Lab Use Only)	
Description/Location	Date	Time	Type	Number of Containers for Analysis Requested	Container Material	Container Size (in MI)	Preservative
104	10/20	6:00	DW	1	Plastic	250 ml	
93		6:10					
89		6:05					
77		6:30					
11		6:10					
119		6:22					
28		6:25					
21		6:35					
7		6:25					
15		6:20					
101		6:24					
109		6:09					
37		6:30					
32		6:46					
95		6:30					
77		6:06					
49		6:01					
		6:27					
		6:45					
		6:20					

Ice:	YES	NO
Cooler:	YES	NO
Sample Temp:	YES	NO
Cooler Seal:	YES	NO
Pickup:	YES	NO
Dropoff:	C	W
Accepted?	YES	NO

Container Material	
Container Size (in MI)	
Preservative	
Comments/Field Data	

Sampled:	Date/Time	Comments
Received:	10/20/2008	
Received:		

Microbac Laboratories, Inc. (MNY) has been selected as the provider of environmental testing services for the New York State Office of Environmental Conservation. By signing this document, you are certifying that you have been informed by MNY of the terms and conditions of the contract.

